



Address Harregatplein 15  
3214 VP Zuidland  
Telephone +31 (0) 181 45 21 20  
Fax +31 (0) 181 45 21 85  
E-mail [info@indexelektro.nl](mailto:info@indexelektro.nl)  
Website [www.indexelektro.nl](http://www.indexelektro.nl)

**EU Declaration of Conformity**  
in accordance with  
**ATEX Directive 2014/34/EU**



<b>Customer</b>	Enovation Controls Ltd.	<b>Order Customer</b>	PO00062956
<b>Manufacturer</b>	Index Elektro BV		
<b>Address</b>	Harregatplein 15 3214 VP Zuidland the Netherlands		
<b>Product Name</b>	Control / Distribution Box		
<b>Type</b>	INDEX.C.CT.0	with ser.nr. 170195 - 16870 to 170195 - 16919	
<b>ATEX Mark</b>	⊕ Ex II 2 G / Ex d...IIB/IIC... T6 to T4 Gb/Gc and/or ⊕ Ex II 2 D / Ex t IIIB/IIIC T80°C to T130°C Db/Dc		
<b>Notified Body</b>	ISSEP, Rue de la Platinerie, B-7340 Colfontaine, Belgium (0492)		
<b>Certificate no.</b>	ISSEP11ATEX019		
<b>Quality Assurance</b>	CML (Certification Management Limited), Unit 1 Newport Business Park, New Port Road, Ellesmere Port CH65 4LZ, UK		
<b>Notified Body no.</b>	2503		
<b>Applicable Standards</b>	EN 60079-0: 2009, compliance is not affected by EN60079-0:2012 EN 60079-1: 2007 EN 60079-31: 2009		
<b>Declaration</b>	The undersigned, representing the manufacturer, herewith declares that the object of the declaration described above is in conformity with the relevant Union harmonisation legislation Directive 2014/34/EU (from April 20th, 2016), when installed and maintained in accordance with the 'Safety and Maintenance Instruction'.		
<b>Name</b>	Ron den Hartigh		
<b>Position</b>	Authorized representative for ATEX		
<b>Signature</b>			
<b>Date</b>	15-3-2017		